

**ADDENDUM #1**  
**Spaulding High School Sports Field Irrigation**  
**Spaulding High School - Rochester, NH**

- 1) Second smaller potable water RPZ is to be 1-1/2". New feed line to snack shack and bath house can be reduced to 1-1/2".
- 2) Track around football field is not to be cut. Any wires or lines that cross track must be bored.
- 3) Any non-track pavement can be cut and patched.
- 4) Baseball and Softball fields valve boxes to be removed and filled.
- 5) Football field 10 valve boxes and quick connects to be removed and filled.
- 6) Dumpster to be provided by owner.
- 7) Unless otherwise specified abandon existing system in place. Any disturbed portions of existing system must be removed enough to make safe.
- 8) Any disturbed electric wires must be repaired by a licensed electrician.
- 9) All disturbed areas of football field must be restored with sod. Baseball, softball, and other areas may be restored with loam and seed.
- 10) Work in a given field must not conflict with the seasonal use of each field for its intended sport.
- 11) See revised bid sheet.

Any questions or concerns can be directed to:

David Totty, Director of Facilities  
Rochester School Department  
Phone: 603-332-3678 \*1145